

HIGH COURT OF PUNJAB AND HARYANA
AT CHANDIGARH

CWP No. 22611 of 2015
Date of decision: October 20,2015

Bhim .,. Petitioner

Versus

State of Haryana and ors. ... Respondents

CORAM: HON'BLE MR.JUSTICE HARINDER SINGH SIDHU

Present: - Mr. Ankur Lal, Advocate
for the petitioner.

HARINDER SINGH SIDHU. J.

The grievance of the petitioner is that Haryana Vidyut Prasaran Nigam is laying a high tension wire of 220 KV, passing through village Badoli at a distance of less than 17.5 metres from the buildings/premises of the petitioner and other residents of the village.

Learned counsel for the petitioner states that as per demarcation report dated 14.10.2015 (Annexure P-5), the distance of the said line is only 24 feet which is against the required minimum distance of 17.5 meters. He further states that in this regard a complaint dated 18.9.2015 (Annexure P-6) was moved to the Deputy Commissioner, Faridabad but no action has been taken thereon so far.

Learned counsel for the petitioner states that at this stage, he would be satisfied if a direction is issued to respondent No. 2 to look into the complaint (Annexure P-6) and take a decision thereon.

Accordingly, without commenting on the merits of the case, the present writ petition is disposed of with a direction to respondent No. 2 to look into the complaint dated 18.9.2015(Annexure P-6) and dispose of the same expeditiously, preferably, within a period of three weeks from the date of receipt of a certified copy of this order.

(Harinder Singh Sidhu)
Judge

20.10.2015
dinesh