

**214 IN THE HIGH COURT OF PUNJAB AND HARYANA AT
CHANDIGARH**

CWP No. 21243 of 2018.

Date of Decision: 02.07.2019.

Narender Kumar @ Narender Singh

... Petitioner

Versus

State of Haryana and others

... Respondents

CORAM : Hon'ble Mr. Justice Jitendra Chauhan

Present : Petitioner in person.

Mr. Rajesh Sheoran, Addl. AG Haryana.

Mr. R.S. Longia, Advocate,
for respondent Nos. 2 to 5.

JITENDRA CHAUHAN.J.(ORAL)

The petitioner, *inter alia*, seeks issuance of a writ in the nature of mandamus directing the respondents to install 63 KVA transformer nearby the tubewell of the petitioner.

Learned counsel for respondent Nos. 2 to 5 informs that the site was visited by the officials of the respondent-department who made the following observations:-

- “1. Checking was carried out in the present of Sh. Baldev Singh s/o Sh. Dolat Ram, Vill. Suchan.*
- 2. During the checking found that tubewell Supply was in running position.*
- 3. Load and voltage checked through the clip on meter capacitor was not installed.*
- 4. Vediography made at site.*
- 5. Length of L.T. Line from Transformer to tubewell Bore 500 feet.”*

It was also noticed that the petitioner had not installed capacitor on his tubewell motor which is essential as the installation of

capacitor would increase about 20% of the voltage. At the time of installation of the tubwell, the petitioner had deposited only the processing charges of Rs.15,000/- on account of service charges and not towards the shifting of the transformer. In the alternate, he further states that if the petitioner is ready and willing, the respondents can also install a separate transformer in pursuance to the communication dated 04.04.2018 (Annexure P-1) provided the petitioner makes the requisite payment of Rs.1,68,375/-.

The petitioner states that now he has installed the capacitor. In this view, of the matter, respondent No.2 is directed to inspect the spot and in case the supply is still found to be erratic and inadequate then the necessary remedial measures be suggested to the petitioner. The petitioner is free to avail the suggested measures after depositing the amount on the prevailing rates of the Corporation.

Disposed of accordingly.

02.07.2019.
SN

(JITENDRA CHAUHAN)
JUDGE

Whether speaking/reasoned :	Yes/No
Whether reportable :	Yes/No