

09.09.2024
Court No.09
Item no.8
CP

WPA No. 11811 of 2024

Shekh Emamul Aulia
Vs.
The State of West Bengal & ors.

Mr. Sajal Kanti Bhattacharyya
Mr. Sarthak Burman
Sk. Raju Ahmed
.... for the Petitioner.

Dr. Madhusudan Saha Roy
....for the WBSEDCL.

Md. Abdur Rakib
Mr. Mojahid Mehedi
.....for the respondent nos. 7
and 9 to 13

Ms. Jhuma Chakraborty
Ms. Munmun Tewary
.....for the State.

The inspection report is taken on record. The Divisional Engineer and Station Manager, Pandua C.C.C. has categorically stated that mandatory clearance has been maintained between the petitioner’s premises and the poles and cables erected by the WBSEDCL, in order to grant electricity to the respondent no. 13. A sketch map has also been produced in this regard. A table containing the measurements is quoted below, for convenience:-

Mandatory clearance in Meter (Feet)	L & MV (upto 440	HV (11KV)	HV (33KV)
--	---------------------	-----------	--------------

	Volt)		
Vertical clearance of OH line from highest point of the building/structure (permanent or temporary)	2.5 Meter (8.0 feet)	3.7 Meter (12.0 feet)	3.7 Meter (12.0 feet)
Horizontal clearance of OH line from nearest point of the building/structure (permanent or temporary)	1.2 Meter (4.0 feet)	1.2 Meter (4.0 feet)	2.0 Meter (6.5 feet)

It appears from the report that a bare conductor at the entrance of the petitioner, as alleged, had not been fixed. The distance between the installations of the distribution company and the proposed meter room of the respondent no. 13, is 71 feet.

As the authorities have maintained the safety regulations, there is no reason to interfere in this writ petition. The police report is also taken on record.

As this court does not find any illegality in the attempt of the distribution company to grant supply to the respondent no. 13 and has maintained all safety and security regulations, connection shall be immediately granted, in accordance with law.

The writ petition is disposed of accordingly.

There shall be no order as to costs.

Parties are directed to act on the basis of the server copy of this order.

(Shampa Sarkar, J.)