



W.P(MD)No.16435 of 2016

WEB COPY

BEFORE THE MADURAI BENCH OF MADRAS HIGH COURT

DATED: 07.11.2024

CORAM

THE HON'BLE MR.JUSTICE K.KUMARESH BABU

W.P(MD)No.16435 of 2016

and

W.M.P(MD)Nos.12001 & 12002 of 2016

M/s.A.D.Textile,
Represented by its Partner,
D.Senthilkumar

... Petitioner

Vs.

- 1.The Tamil Nadu Generation and Distribution Corporation Limited (TANGEDCO),
Represented by its Chairman & Managing Director,
No.144, Anna Salai,
Chennai-2.
- 2.The Superintending Engineer,
Karur Electricity Distribution Circle,
Karur.
- 3.The Central Electricity Authority (CEA),
Represented by its Chairperson,
6th Floor,
Sewa Bhavan,
R.K.Puram,
New Delhi.



W.P(MD)No.16435 of 2016

4. Tamil Nadu Electricity Regulatory Commissioner
(TNERC),

Represented by its Secretary,
No.19-A, Rukmani Lakshmipathy Salai,
(Marshall's Road),
Egmore,
Chennai-8.

... Respondents

PRAYER : Writ Petition filed under Article 226 of the Constitution of India, praying this Court to issue a Writ of Certiorarified Mandamus, calling for the records relating to the impugned order passed by the second respondent in his proceedings Lr.No.SE/KEDC/KRR/DFC/AS/HT/F.59/D.331/2016, dated 03.08.2016 and quash the same and consequently forbear the respondents 1 and 2, their men, agents, representatives and / or anyone claiming through or under them from in any manner insisting on harmonic control and levying, demanding or collecting any charges or compensation for harmonics dumping from the petitioner firm in respect of their service connection number HT SC 59/Karur and pass such other further or other orders as this Court.

For Petitioner : Mr.K.Suresh

For Respondents : Mr.S.Deenadhayalan
Standing Counsel



W.P(MD)No.16435 of 2016

WEB COPY

ORDER

The present writ petition has been filed to quash the order, dated 03.08.2016 passed by the second respondent and consequently forbear the respondents 1 and 2, their men, agents, representatives and / or anyone claiming through or under them from in any manner insisting on harmonic control and levying, demanding or collecting any charges or compensation for harmonics dumping from the petitioner firm in respect of their service connection number HT SC 59/Karur.

2. The learned Standing Counsel appearing for the Department would submit that the Central Electricity Authority [Technical Standards for Connectivity to the Grid] Regulations, 2007 would indicate that the harmonic distortion would only be installed with subscribers having more than 33 KV and above connections and the same would not be applicable to the petitioner as the petitioner had availed only 11 KV connection.



W.P(MD)No.16435 of 2016

WEB COPY

To

- 1.The Chairman & Managing Director,
Tamil Nadu Generation and Distribution
Corporation Limited (TANGEDCO),
No.144, Anna Salai,
Chennai-2.
- 2.The Superintending Engineer,
Karur Electricity Distribution Circle,
Karur.
- 3.The Chairperson,
Central Electricity Authority (CEA),
6th Floor,
Sewa Bhavan,
R.K.Puram,
New Delhi.
- 4.The Secretary,
Tamil Nadu Electricity Regulatory Commissioner
(TNERC),
No.19-A, Rukmani Lakshmipathy Salai,
(Marshall's Road),
Egmore,
Chennai-8.



WEB COPY



W.P(MD)No.16435 of 2016

K.KUMARESH BABU, J.

BTR

Order made in
W.P(MD)No.16435 of 2016

07.11.2024