

2025:PHHC:169346



**IN THE HIGH COURT OF PUNJAB AND HARYANA  
AT CHANDIGARH**

117

**CWP No.21231 of 2025 (O&M)  
DATE OF DECISION: 04.12.2025**

**RANJIT SINGH**

**..PETITIONER**

**VS.**

**STATE OF PUNJAB AND OTHERS**

**..RESPONDENTS**

**CORAM: HON'BLE MR. JUSTICE SUVIR SEHGAL**

Present: Mr. Sarthak Jindal, Advocate for the petitioner.

Mr. Kanav Singla, Asstt. AG, Punjab.

Mr. Rajan Singh Dadwal, Advocate  
For the applicant in CM-11202-CWP-2025.

Mr. Arpan Sabharwal, Advocate  
for respondents No. 2 to 5-PSPCL.

\*\*\*\*

**SUVIR SEHGAL, J.(ORAL)**

1. In compliance of order dated 06.08.2025 passed by this Court, a Committee was constituted and a report has been submitted. The conclusion arrived at by the Committee is reproduced hereunder:-

*“The committee, constituted by the Chief Engineer/Operation, Central zone Ludhiana, examined the facts presented by both the parties (Party No.1 Committee/Village Residents of Gurudwara Shri Ramsar Sahib, Village Leel, Ludhiana and Party No.2-Ranjit Singh son of Shri Mewa Singh resident of Village Leel, Ludhiana) along with data submitted by Assistant*

**CWP No.21231 of 2025 (O&M)****-2-**

*Executive Engineer/Operation, Sub Division Pakhowal, concluded as follows:-*

- 1. The work of installing a new 100 KVA transformer near Gurudwara Shri Ramsar Sahib was started by the department almost a year ago, to improve the electricity supply in the village. This transformer was being installed to resolve the problem of voltage drops of the area. The new transformer being installed as per the instructions of PSPCL and is technically correct. The work of the installed transformer has been done as per the rules of the department. But, the transformer was not energized, as the 11 KV Cable (insulated cable), which was to be laid along the already existing LT Line and by installing additional poles (as required), was not laid due to the resistance from the residents of area/road/street. Hence this work is incomplete. The residents of area/road/street also opposed the installation of the transformer before the committee.*
- 2. The Party No.2 (Ranjit Singh son of Mr. Mewa Singh resident of village Leel, Ludhiana) suggested the Committee to install the transformer at a new place (Murabba and Khasra No.264) instead of present position. The suggested place was a private property (ownership of property and other documents are attached as per Annexure-7) and the property owners raised the objections for installing the transformer at their place. So, the transformer cannot be installed at that location (Murabba and Khasra No.264).*
- 3. To improve the supply/voltage, the committee suggests to increase the capacity of already existing transformer from 100 KVA to 200 KVA and by laying a new LT Circuit (insulated cable) alongside the already existing LT Line, the*

2025:PHHC:169346



CWP No.21231 of 2025 (O&M)

-3-

*supply/voltage of the Gurudwara Shri Ramsar Sahib & near by area can be improved.*

*The report is submitted to the office of Chief Engineer/Operations (Central zone) Ludhiana for further action”.*

2. In view of the above report, writ petition is disposed of. PSPCL-respondents No. 2 to 5 are directed to implement the report of the Committee as expeditiously as possible.
3. Pending application(s), if any, is/are also disposed of.

**December 04, 2025**  
Poonam Sharma

**(SUVIR SEHGAL)**  
**JUDGE**

Whether speaking/reasoned Yes/No

Whether Reportable Yes/No