



**IN THE HIGH COURT OF PUNJAB AND HARYANA  
AT CHANDIGARH**

116

CWP-24911-2025

Date of Decision: 23.03.2026

**Parvesh Jangra****...Petitioner****Versus****Uttar Haryana Bijli Vitran Nigam Limited and another****...Respondents****CORAM: HON'BLE MR. JUSTICE JAGMOHAN BANSAL**

Present: - Mr. Amandeep Bidhan, Advocate for the petitioner

Mr. Tushar Kaushik, Advocate

for Mr. Ravish Kaushik, Advocate for the respondents

\*\*\*

**JAGMOHAN BANSAL, J.** (Oral)

1. The petitioner through instant petition under Articles 226/227 of the Constitution of India is seeking directions to respondent-authorities to remove the electricity pole installed near his plot. He is also seeking direction to respondents to decide his legal notice dated 22.07.2025.
2. The petitioner submits that the electricity pole supporting 33,000 Volts wires has been installed at a distance of 4 feet from his plot which is less than prescribed 6.6 feet limit and is in violation of Rule 80(2) of Indian Electricity Rules, 1956.
3. Affidavit dated 20.03.2026 of Mr. Pawan Narula, Executive Engineer, Construction Division, UHBVN, Kurukshetra filed on behalf of respondents is taken on record. Registry is directed to tag the same at an appropriate place.



4.            Learned counsel for the respondents submits that as per aforesaid affidavit, the Conductor would be installed at more than 2 meters away from the building. Needful would be done within one week from today.
5.            In the wake of statement of learned counsel for the respondents, the petition stands disposed of.

(JAGMOHAN BANSAL)  
JUDGE

23.03.2026  
Mohit Kumar

|                           |        |
|---------------------------|--------|
| Whether speaking/reasoned | Yes/No |
| Whether reportable        | Yes/No |